

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:07 pm

PWS ID: UTAH13015 **Name:** CORAL PINK SAND DUNES
Legal Contact: UTAH STATE PARKS SOUTHWEST REG **Rating:** Approved
 LARRY D GRAY **Rating Date:** 04/09/1996
Address: 585 N MAIN **Activity Status:** Active
 CEDAR CITY, UT 84721
Phone Number: 435-586-4497
City Served (Area):
County: KANE COUNTY
System Type: Non-community **Last Inv Update:** 08/01/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 08/26/2008 **Total Dsgn Cap:**
Population: 75 **Surveyor:** JOHN L CHARTIER **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	GRAY, LARRY D	SW REGION M/	435-586-4497		larrygray@utah.gov

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	2
Commercial	Unknown	0	20
			22 Total Svc Connections

Storage

Total Storage: 35,000 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	OLD TANK	Ground	12,500 GAL	Steel		I	
ST002	UPPER TANK 1	Ground	20,000 GAL	Steel		A	
ST003	UPPER TANK 2	Reservoir	15,000			A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	SAND DUNES OLD WELL 1	Inactive	WL	6	10 GPM		Yes	GW	Other		
WS002	SAND DUNES WELL 2	Active	WL	8	25 GPM	25 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.